

Remote Control Setting	Buttons	Remarks																												
		Press the 'ON/OFF' button, the light goes to constant on/off mode. sensor is disabled. Press any button to quit from this mode and the sensor starts to work.																												
		Press 'Reset' button, all parameters are same as settings of DIP switch factory settings.																												
		Press 'Sensor motion' button, the light quits from the constant on/off mode, and the sensor starts to work (The latest setting stays in validity).																												
		Press 'DIM Test' button, the 1-10V dimming works to test whether the 1-10Vdc dimming ports are connected properly. After 2s, it returns to the latest setting automatically.																												
		Short press 'DIM+/DIM-' button to transmit dimming signal. The brightness of the lamp adjusts at 5% per unit.																												
		Long press >3s, sensor will take current light level as target lux level to dim up/down load automatically according to the change of ambient light level.																												
		<table border="1"> <thead> <tr> <th>Scene Options</th> <th>Detection Area</th> <th>Hold Time</th> <th>Stand-by period</th> <th>Stand-by dim-level</th> <th>Daylights Sensor</th> <th>Induction Mode</th> </tr> </thead> <tbody> <tr> <td>QS1</td> <td>100%</td> <td>30S</td> <td>1min</td> <td>10%</td> <td>5Lux</td> <td>Hs</td> </tr> <tr> <td>QS2</td> <td>100%</td> <td>1min</td> <td>3min</td> <td>10%</td> <td>10Lux</td> <td>Hs</td> </tr> <tr> <td>QS3</td> <td>100%</td> <td>5min</td> <td>10min</td> <td>10%</td> <td>30Lux</td> <td>Hs</td> </tr> </tbody> </table> <p>Note: Detection area /Hold time / Stand-by period / Stand-by dim level / Daylight sensor can be adjusted by pressing the corresponding button. The latest setting will stay valid.</p>	Scene Options	Detection Area	Hold Time	Stand-by period	Stand-by dim-level	Daylights Sensor	Induction Mode	QS1	100%	30S	1min	10%	5Lux	Hs	QS2	100%	1min	3min	10%	10Lux	Hs	QS3	100%	5min	10min	10%	30Lux	Hs
Scene Options	Detection Area	Hold Time	Stand-by period	Stand-by dim-level	Daylights Sensor	Induction Mode																								
QS1	100%	30S	1min	10%	5Lux	Hs																								
QS2	100%	1min	3min	10%	10Lux	Hs																								
QS3	100%	5min	10min	10%	30Lux	Hs																								
		Press the 'TEST 25' button can enter the test mode anytime. At the mode, the sensor parameter as below: Detection Area is 100%, Hold is 2s, Stand-by Dim Level is 10%, Stand-by Period is 0s, daylight sensor disable. This function only for testing. Quit the mode by pressing 'RESET' or any other function buttons.																												
		Press 'HS' button to set the detection area to be high sensitive. Press 'LS' button to set the detection area to be low sensitive. The adjustment bases on the 'Detection Area' parameter you set.																												
		Detection Area Set up detection area: 5Lux / 15Lux / 30Lux / 50Lux / 100Lux / 150Lux / Disable																												
		Stand-by period. Set up stand-by time: 0s / 10s / 1min / 3min / 5min / 10min / 30min / +-																												
		Hold time Set up hold time: 5s / 30S / 1min / 3min / 5min / 10min / 20min / 30min																												
		Stand-by dim level Set up stand-by dim level: 10% / 20% / 30% / 50%																												
		Detection Area Set up detection area: 25% / 50% / 75% / 100%																												
		Remote Distance Toggle bottom can set the remote distance of remote control and sensor.																												

Remote control and code setting conversion

- Dip switch setting convert to remote control
Press any button except "Reset" on the remote control, and the sensor settings convert to the function currently selected by the remote control. (No function button settings invalid)
- Remote control convert to DIP switch setting
 - Press the "RESET" button on the remote control and all settings return to the DIP switch settings of the sensor.
 - Turn off the power, toggle any DIP switch, connect to the power, and all settings return to the DIP switch settings when supply power again.

Unique design of infrared Transmitting device

