



Installation procedure

Carefully read the installation instructions and ensure the mains supply is isolated before installation. All electrical work must be undertaken by a qualified contractor to ensure compliance with latest edition BS7671 and IEE/IET wiring regulations.

Step 1:

Remove the Existing Emergency Pack, including the LED indicator.



Step 2:

Fix the Emergency Pack to the tray using the tape provided.



Step 3:

Connect the Unswitched Input and Output to LED connections as shown.



Step 4:

Install the new LED Indicator as shown.

